

COMPACT WEATHER STATION WS510-UMB

Item-No.: 423.312



similar to figure

DESCRIPTION OF FUNCTIONS

The WS510-UMB compact weather station is used to measure air temperature, relative humidity, solar irradiance, air pressure, wind direction and wind speed. Furthermore, it has an RS485 Modbus interface, which guarantees an easy connection to every meteocontrol data logger.

TECHNICAL DATA

Supply voltage for the sensors:	4 ... 32 V DC, limitations apply in case of supply voltages lower than 12 V DC, recommended is 24 V DC
Power consumption sensors:	3,48 W (without heating)
Supply voltage heating:	12 ... 24 V DC, functional restrictions in winter operation on voltages lower than 24 V DC
Power consumption heating:	20 W
Interface:	RS485, 2 wire, half-duplex
Operating temperature:	-50 ... 60 °C
Rel. humidity:	0 ... 100 % r.h.
Protection class:	IP 66
Cable length:	10 m
Gewicht:	approx. 1,5 kg
Dimensions:	Ø approx. 150 mm, height approx. 376 mm

IRRADIANCE MEASUREMENT

ISO 9060 classification:	Secondary standard pyranometer (CMP10)
Principle:	Thermal detector
Spectral range (50% points):	285 ... 2800 nm
Measuring range:	0...4000 W/m ²
Inclination error (at 1000 W/m ²):	<0,2 %
Directional error (at 80° and 1000 W/m ²):	<10 W/m ²
Non-linearity (0 ... 1000 W/m ²):	<0,2 %
Stability deviation (per annum):	<0,5 %
Response time (95%):	<5 s
Temperature dependence of the sensitivity:	<1 % (-10 ... 40 °C)

TEMPERATURE

Principle:	NTC
Measuring range:	-50 ... 60 °C
Accuracy:	±0,2 °C (-20 ... 50 °C), otherwise ±0,5 °C (> -30 °C)

REL. HUMIDITY

Principle:	capacitive
Measuring range:	0 ... 100 % r. h.
Accuracy:	± 2 % r. h.

AIR PRESSURE

Principle:	MEMS capacitive
Measuring range:	300 ... 1200 hPa
Accuracy:	±0,5 hPa

WIND DIRECTION

Principle:	Ultrasound
Measuring range:	0 ... 359.9 °
Accuracy:	< 3 ° RMSE, > 1.0 m/s

WIND SPEED

Principle:	Ultrasound
Measuring range:	0 ... 75 m/s
Accuracy:	± 0.3 m/s or 3 % (0 ... 35 m/s) RMS (whichever figure is the higher) ± 5 % (> 35 m/s) RMS

CONFIGURATION

Interface:	RS485
Protocol:	Modbus RTU
Baud rate:	19200
Address range:	61 to 70, see identification label
Data format:	8N1

MEASUREMENT VALUES RECORDED

E_AH_REL	Humidity relative
E_AP_REL	Air pressure relative
E_W_D	Wind direction
E_G_U	Irradiance horizontal
E_AT	Air temperature
E_W_S	Wind speed
E_RF_ABS	Precipitation absolute
E_RF_I	Precipitation / hour
E_AH_ABS	Humidity absolute
E_AP_ABS	Air pressure absolute

meteocontrol GmbH | Spicherer Straße 48 | 86157 Augsburg | Germany | phone +49 (0)821 34666 - 0 |
 fax +49 (0)821 34666 - 11 email info@meteocontrol.com | web www.meteocontrol.com

meteocontrol North America | 1110 W. Lake Cook Road Ste 370 | Buffalo Grove | Illinois | phone +1 (224) 310-5700
 email info-na@meteocontrol.com | web www.meteocontrol.com