

GRID CODE COMPLIANCE (GCC) VERIFICATION SERVICES



Item No.: 557.220 - 557.224

SECURING PLANT CONTROL CHARACTERISTICS FOR RELIABLE GRID CODE COMPLIANCE

DESCRIPTION OF FUNCTIONS

Compliance with grid connection requirements is crucial for a stable grid supply. In many countries, the measurement of the plant controller is also a prerequisite for project certification and is therefore decisive for the successful implementation of solar power plants.

The type and scope of the so-called Site Acceptance Tests (SAT) differ from market to market and often depend on the plant size (installed capacity) and voltage level. With the Grid Code Compliance (GCC) Engineering Services we offer customized services for the verification of power plant control from standardized functional tests to project-specific compliance test procedures and compliance test reports. Market-specific and contractual agreements between grid operator and connected party (owner) can be taken into account on a project-specific basis.

OVERVIEW

In principle, the verification can be either standardized or project-specific. If the grid operator defines specific requirements for compliance tests, the verification must be carried out project-specific in accordance with the specified framework conditions.

FUNCTIONAL TEST

557.220 Standard test protocol

STANDARD VERIFICATION

557.221 Standard test procedure, system-related

557.222 Standard test report, system-related

PROJECT-SPECIFIC VERIFICATION

557.223 Compliance test procedure, project-specific

557.224 Compliance test report, project-specific

	ASSESSMENT		DOCUMENTATION		
	Qualitative	Quantitative	Standard	Project-specific	Raw data (*.txt)
557.220 Standard test protocol	●		●		
557.221 Standard test procedure, system-related			●		
557.222 Standard test report, system-related		●	●		●
557.223 Compliance test procedure, project-specific				●	
557.224 Compliance test report, project-specific		●		●	●

ADDITIONAL NOTES

Qualitative assessment:	Testing whether setpoints can generally be reached and maintained
Quantitative assessment:	Determination of control characteristics such as steady-state error, rise time, settling time and overshoot (only project-specific if required)
Standard:	Test protocol / test procedure according to the company's own (meteocontrol) standard in reliance to Network Code (NC) Requirements for Generators (RfG) / EU regulation 2016/631
Project-specific:	Test procedure according to country- /and/or project-specific requirements
Setpoint command methods:	Only the setpoint command methods required by the grid operator are tested
Measurement raw data:	Provision of measurement raw data with an interval of 200 ms in format *.txt
Site Acceptance Testing (SAT):	Testing according to drafted test procedure (standard / project-specific) is not included in the scope of delivery, but can be offered on an hourly rate basis
Revisions:	Revisions are charged on the basis of hourly rates

SITE ACCEPTANCE TESTS (SAT)

Active power:	Active power decrease at overfrequency (LFSM-O) Active power controllability
Reactive power:	Reactive power capability (only project-specific if required) Voltage control Q (V droop) Reactive power control Q_{var} Power factor control $\cos \varphi_{var}$ Characteristic curve Q (P) Characteristic curve Q (U)
Behaviour in the events of technical faults:	Communication failure at an interface for setpoint value transmission Communication failure at an interface for correction value transmission Communication failure at an interface for actual value transmission

STANDARD VERIFICATION (557.221 / 557.222)

	Setpoint steps	Step size	Control range ¹⁾
Active power decrease at overfrequency (LFSM-O)	8	not fixed	50.0 ... 51.5 Hz
Active power controllability	10	10 % P/P_{max}	0 ... 100 % P/P_{max}
Voltage control Q (V droop)	16	0.01 V/V_c	0.95 ... 1.05 V/V_c
Reactive power control Q_{var}	18	5 % Q/P_{max}	-30 ... 30 % Q/P_{max}
Power factor control $\cos \varphi_{var}$	15	0.01	-0.95 ... 0.95
Characteristic curve Q (P)	10	10 % P/P_{max}	-33 ... 0 % Q/P_{max}
Characteristic curve Q (V)	18	0.01 V/V_c	-33 ... 33 % Q/P_{max}

Further information: www.meteocontrol.com

¹⁾ Negative reactive power values ($Q / \cos \varphi$) correspond to a reactive power absorption from the grid (underexcited operating mode, voltage decreasing), positive reactive power values ($Q / \cos \varphi$) correspond to a reactive power injection into the grid (overexcited operating mode, voltage increasing).